

COMMERCIAL TRIMRIB ROOFING TYPICAL BARGE (Birds Beak)

DETAIL NO.

CTR002B

DATE DRAWN

16/08/12

FILE REFERENCE

RI-CTR002B.DWG

SCREW FIXING WITH
12x25 TYPE 17 TEK & NEO
OR 4.8mm ALUM RIVETS
MIDSPAN WHERE APPLICABLE
(offset for clarity)

10mm GAP IF COMPLIANCE
WITH E2/AS1 REQUIRED

ROOFING INDUSTRIES
TRIMRIB

UNDERLAY LAID OVER
SAFETY NETTING

GAP 5mm MAX TO CLEAR
OF TROUGH OF ROOFING

12x55mm STEEL TEK &
NEO WITH SELECTED
WASHER SYSTEM

STEEL PURLIN

STEEL GIRT

ROOFING INDUSTRIES
0.55 BARGE FLASHING

STOP END SHEET


PROFIED FOAM CLOSURE
(Foam closure strip only required in high
risk situations of wind blown moisture entering)

BIRDS BEAK FLASHING FOLDED & FIXED
THROUGH RIBS WITH 12g x 55mm STEEL TEK

ROOFING INDUSTRIES TRIMRIB
(OR OTHER PROFILE) WALL CLADDING

BUILDING WRAP (IF REQUIRED)

12x20 STEEL TEK PAN FIXED



Bird's beak dimension
may vary between
manufacturing locations.

BIRD'S BEAK at bottom
edge of vertical flashing

NOTES:

- These details are generally in compliance with the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure are indicative only and are the responsibility of the building designer.
- Thermal break or cavity battens may be required in some circumstances.
- Underlay selection and building wrap types are the responsibility of the designer. Alternative support to galvanised netting should be used in severe coastal environments including when aluminium is used.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice www.metalroofer.org.nz & www.roof.co.nz
- Where necessary adjust drawings for purlin battens or cavity battens.
- Details are for steel based materials, other substrate may require some changes.



TYPICAL BARGE (Birds Beak)

1:5

©COPYRIGHT DETAIL 2012

