

COMMERCIAL TRIMRIB ROOFING PARAPET HEAD APRON - Soft Edge

EX 50mm H3.1 TIMBER CAPPING SUPPORT ON DPC

SEPERATION BARRIER BETWEEN CONCRETE
& FLASHING (SELF ADHESIVE TAPE OR SIM)

R.I. 0.55mm PARAPET FLASHING

PROFILED FOAM CLOSURE STRIP (2)

12x55 STEELTEK & NEO WITH
SELECTED WASHER SYSTEM

R.I. 0.55mm APRON FLASHING
SOFT EDGE DRESSED OVER
TRIMRIB

ROOFING INDUSTRIES
TRIMRIB

UNDERLAY LAID OVER
SAFETY NETTING

STEEL PURLIN & CLEAT

STRUCTURAL STEEL

5° min

90min

FIX CAPPING TO CONCRETE WITH MASONRY
FASTENERS AT 600mm CRS

HEM TO
FLASHING
EDGE

100min LAP

200min COVER

STOP END

20min GAP

CONCRETE WALL

DETAIL NO.

CTR007B

DATE DRAWN

28/03/12

FILE REFERENCE


RI-CTR007B.DWG

NOTE:

- (1) MINIMUM PITCH 3°
- (2) FOAM CLOSURE STRIP ONLY REQUIRED IN HIGH
RISK SITUATIONS OF WIND BLOWN MOISTURE ENTERING.

NOTES:

- These details are generally in compliance with the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure are indicative only and are the responsibility of the building designer.
- Thermal break or cavity battens may be required in some circumstances.
- Underlay selection and building wrap types are the responsibility of the designer. Alternative support to galvanised netting should be used in severe coastal environments including when aluminium is used.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice www.metalroofer.org.nz & www.roof.co.nz
- Where necessary adjust drawings for purlin battens or cavity battens.
- Details are for steel based materials, other substrate may require some changes.



Bird's beak dimension
may vary between
manufacturing locations.

A PARAPET DETAIL
1:5

©COPYRIGHT DETAIL 2012

