RESIDENTIAL RIBLINE® WALL HORIZONTAL ON CAVITY SILL FLASHING FOR HORIZONTAL CLADDING (RECESSED WINDOW/DOOR)

SEPARATION OF METAL CLADDING & BATTEN

Detail Number: RI-RRWHC-130C

Date drawn: 25/07/2024

Scale: 1:5@ A4

ALUMINIUM WINDOW **PACKERS** WANZ SUPPORT BAR 5mm GAP DO NOT SEAL AIR SEAL THIS JUNCTION **BUILDING WRAP DRESSED** INTO OPENING WITH 50mm **ROOFING INDUSTRIES** RETURN TO INSIDE OF FRAME SILL FLASHING WITH 10° FALL WITH WINDOW FLASHING TAPE FLUSH WITH SCREW FIXING INSIDE OF FRAME (CREST OR TROUGH FIXING) **ROOFING INDUSTRIES** 'RIBLINE' SOAKER FLASHING

GENERAL NOTES:

- These details are to be read with Roofing Industries Ribline Product Technical Statement.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
 - Fixings: The designer needs to check the screw manufacturer's technical data of the selected screw type for the design wind load and the material being fastened to.

DETAIL ANNOTATION:

- I. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER
- LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION
- 3. CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS
 MUST BE SEPARATED FROM METAL CLADDING BY DPC, WALL
 UNDERLAY, PVC OR PAINTING
- 4. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED
- 5. REFER TO UNDERLAY MANUFACTURERS REQUIREMENTS FOR INSTALLATION RECOMMENDATIONS



Sill flashings stop ended to receive jamb flashings (Dimensions are indicative only & show minimum lap covers) Copyright detail C

