## EUROSTYLE SPANLOK™ VARIABLE PAN **ROOFING ON PURLINS INTERNAL GUTTER**

OVERALL GUTTER WIDTH 300 mm min. **ROOFING INDUSTRIES** EUROSTYLE SPANLOK™ (8) STOPEND 109 mm 50 mm ROOF UNDERLAY min. min 30 mm min. freeboard (2) 60 mm 1. depth (2) ROOF STRUCTURE NOT SHOWN **GUTTER BOARDS** 

DETAIL ANNOTATION:

5.

- 1. GUTTERS INSTALLED OVER ROOF UNDERLAY IF GUTTER BOARDS ARE TREATED TIMBER
- 2 INTERNAL GUTTER SHALL BE SIZED TO SUIT THE ROOF CATCHMENT AREA, BUT SHALL BE NO LESS THAN SHOWN IN THIS FIGURE. (REFER E2/AS1 FIG. 52)
- INTERNAL GUTTER SHOULD BE MADE FROM 3. NONFERROUS METAL'S COMPATIBLE WITH THE ROOFING MATERIAL. 4.
  - GUTTER SIZES TO BE CALCULATED FROM E1/AS1
  - ALTERNATIVELY REFER TO MRM COP
- 6 HIGH TO EXTRA HIGH WIND ZONE DOUBLE FIX UNDERFLASHINGS
- 7. FASTENERS TO BE COMPATABLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 8. CLIPS OMITTED FOR CLARITY

## GENERAL NOTES:

- These details are to be read with Roofing Industries SPANLOK™ Product Technical Statement and installation guide.
- These details are generally in compliance with E2/AS1 and/or the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimatley responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure including cavity battens are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1.
- Details are for steel based materials, other substrates may require some changes.
- All dimensions are nominal



Copyright detail

(C) <sub>2024</sub>

## Detail Number: RI-ESVPRRPUR-090 Date drawn: 20/05/2024

## Scale: 1:5@ A4